

DATE: April 14, 2025

HURST-ROSCHE, INC.
1400 E. Tremont Street
Hillsboro, Illinois 62049
217-532-3959

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 1 TO THE BIDDING DOCUMENTS FOR

**Sandoval HS Toilet Renovations
Sandoval C.U.S.D. 501
859 West Missouri Avenue
Sandoval, Marion County, Illinois
HR Project # 150-0175**

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated March 24, 2025. Acknowledge receipt of this addendum in the space provided on the Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

Upon receipt of this addendum, please sign below and email to Hurst-Rosche, Inc. at tdownen@hurst-rosche.com 24 hours of receipt.

RECEIVED BY:	_____
	Company Name/Authorized Representative
DATE:	_____

DRAWINGS

- A. SHEET A-102
 - 1. **REVISE** Demo Keyed Note #1 to read as follows: “DEMO EXG. PLUMBING FIXTURES & ALL RELATED ACCESSORIES. CONTRACTOR SHALL REMOVE THE SOUTHERN MOST WATER CLOSET IN WOMEN’S TOILET 111 AND RETURN WATER CLOSET TO THE OWNER.”
 - 2. **ADD** Demo Keyed Note #14: “CAREFULLY SALVAGE EXG. DEDICATION AND OTHER PLAQUES AND PREPARE FOR RE-INSTALLATION IN NEW LOCATION AS DIRECTED BY OWNER.”

This addendum consists of 2 pages.

B. SHEET A-103

1. **ADD** General Note to Door Schedule and 3/A-103 to read as follows: “THE USE OF 7’-0” DOOR SLABS WITH 4” FRAME HEADS IN LEIU OF 7’-2” DOOR SLABS WITH 2” FRAME HEADS IS ACCEPTABLE FOR DOORS 110 & 111. THE OVERALL ASSEMBLY HEIGHT SHALL STILL BE 7’-4”.”

C. SHEET P-101

1. **ADD** the following general note: “CONTRACTOR SHALL CAREFULLY DEMOLISH ALL (6) LAVATORY FAUCETS INDICATED FOR REMOVAL ON THIS SHEET AND RETURN FAUCETS TO THE OWNER.”
2. **ADD** the following general note: “CONTRACTOR SHALL RETURN ALL DEMOLISHED COPPER PIPING TO THE OWNER.”
3. **ADD** the following general note: “CONTRACTOR SHALL REMOVE THE SOUTHERN MOST WATER CLOSET IN WOMEN’S TOILET 111 AND RETURN WALL CLOSET TO THE OWNER.”

This addendum **DOES NOT** alter the previously published bid date of **Wednesday, April 16, 2025, 2:00 PM**, prevailing time, at **Sandoval CUSD 501**.

Sincerely,
HURST-ROSCHE, INC.



Timothy L. Downen, AIA, LEED AP
cc: All plan holders