

DATE: 02-15-2021

HURST-ROSCHE, INC.  
1400 E. Tremont Street  
Hillsboro, Illinois 62049  
217-532-3959

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 1 TO THE BIDDING DOCUMENTS FOR

**SUMMER 2021 H/LS IMPROVEMENTS**  
**EAST ALTON/WOOD RIVER HIGH SCHOOL**  
**EAST ALTON/WOOD RIVER CHSD NO. 14**  
**WOOD RIVER, MADISON COUNTY, ILLINOIS**  
**HR # 150-2830**

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated February 8, 2021. Acknowledge receipt of this addendum in the space provided on the Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

\*\*\*\*\*

**Upon receipt of this addendum, please sign below and email to Hurst-Rosche, Inc. at [tdownen@hurst-rosche.com](mailto:tdownen@hurst-rosche.com) within 24 hours of receipt.**

<b>RECEIVED BY:</b>	_____
	<b>Company Name/Authorized Representative</b>
<b>DATE:</b>	_____

**SPECIFICATIONS**

- A. 001116 Invitation to Bid
  - 1. **DELETE** the Paragraph referencing the bid opening in its entirety and **REPLACE** with the following Paragraph “The Owner will receive Bids until **2:30 PM** local prevailing time on **Thursday, the 4<sup>th</sup> day of March, 2021**, at **East Alton/Wood River CHSD No. 14, 777 North Wood River Ave., Wood River, Illinois 62095** for the following work:”
  - 2. **DELETE** the Paragraph referencing the Pre-Bid Meeting in its entirety and **REPLACE** with the following Paragraph “A Pre-bid Meeting will be held **Monday, the 22<sup>nd</sup> day of February, 2021, at 11:00 AM** prevailing time, at **East Alton/Wood River CHSD No. 14, 777 North Wood River Ave., Wood River, Illinois 62095.**”

This addendum consists of 2 pages.

- B. 002114 Instructions to Bidders - AIA
1. **DELETE** Paragraph 1.4.B in its entirety and **REPLACE** with the following: **“Pre-Bid Meeting: February 22, 2021, 11:00 AM, East Alton/Wood River CHSD No. 14, 777 North Wood River Ave., Wood River, Illinois 62095.”**
  2. **DELETE** Paragraph 1.4.E in its entirety and **REPLACE** with the following: **“Bid Opening: March 4, 2021, 2:30 PM, East Alton/Wood River CHSD No. 14, 777 North Wood River Ave., Wood River, Illinois 62095**
- C. 26 05 19 Low-Voltage Electrical Power Conductors and Cables
1. **ADD** the following as Paragraph 3.6, “CONDUCTOR MATERIAL APPLICATIONS”.
  2. **ADD** the following as Paragraph 3.6.A, “Branch Circuits: Copper. Solid for No. 10 AWG and smaller, stranded for No. 8 AWG and larger”.
  3. **ADD** the following as Paragraph 3.6.B, “Power-Limited Fire Alarm and Control: Solid for No. 12 AWG and smaller”.
- D. 26 05 33 Raceways and Boxes for Electrical Systems
1. **ADD** the following to Paragraph 2.3.G, “or 2-1/4 inches by 4 inches by 2-1/8 inches deep.”
- E. 26 27 26 Wiring Devices
1. **ADD** the following as Paragraph 1.1.A.2, “GFCI receptacles, 125V, 20 A.”
  2. **ADD** the following to Paragraph 2.2.A, “125 V, 20 A”.

## **DRAWINGS**

- A. ME-102 FLOOR PLANS
1. **DELETE** “1300” from Nominal Lumens column of Light Fixture Schedule for Fixture P2 and **REPLACE** it with, “2600”.
  2. **DELETE** Note #4 of Exhaust Fan Schedule and **REPLACE** it with, “FAN SHALL BE INTERLOCKED WITH LIGHTING CONTROLS SO THAT THE FAN IS IN OPERATION WHEN THE TOILET ROOM WHERE IT IS INSTALLED IS OCCUPIED”.
  3. **DELETE** “INDICATING” from Keyed Notes #6 and #7 and **REPLACE** it with, “NOTIFICATION”.
- B. ME-101 DEMOLITION PLANS
1. **DELETE** “EXPOSED” from Keyed Note #9 and **REPLACE** it with, “CONCEALED”.
  2. **ADD** General Note #10 as follows, “DISCONNECT AND REMOVE ANY ABANDONED WIRING AND RACEWAYS THAT ARE NO LONGER TO BE USED. PRESERVE INTEGRITY OF EXISTING REMAINING CIRCUITING.”

This addendum **DOES** alter the previously published bid date of **Thursday, February 25, 2021, 2:30 PM**, prevailing time, at **East Alton/Wood River CHSD No. 14, 777 North Wood River Ave., Wood River, Illinois 62095**. The new bid date is **Thursday, March 4, 2:30 PM**, prevailing time, at **East Alton/Wood River CHSD No. 14, 777 North Wood River Ave., Wood River, Illinois 62095**.

Sincerely,

HURST-ROSCHKE, INC.



Timothy L. Downen, AIA, LEED AP  
cc: All plan holders

This addendum consists of 2 pages.