



HURST-ROSCHE, INC.

PROJECT:
CITY HALL ROOF REPLACEMENT
CITY OF COLUMBIA
700 NORTH GARDEN STREET
COLUMBIA, TN 38401
Solicitation #437-0924-05
HR Project No. 350-1234

ADDENDUM #4 (Date: 10/01/2024)

CONTENTS

Clarifications:

1. Existing roof metals including but not limited to edge metals and fascia shall be demolished with new roof metals, new edge metals and new fascia provided as depicted in the drawings.
2. Provide specified vapor retarder at all metal deck roof areas as specified and shown in the drawings at detail 1/A-602.
3. Vapor retarder not provided at roof area 'B'.

Changes to the Project Drawings:

Sheet A-601: Provide vapor retarder at all details between metal deck and insulation.

Changes to the Project Manual:

Section 002114 Instructions to Bidders, 1.5.D Latest Time to Issue an Addendum: Change to **2:00 PM, Tuesday, October 1, 2024.**

Attached Documents: None.

Total number of pages Addendum #4 – 1 page.



10/01/2024

DATE

04/30/2026

LICENSE EXPIRES

END OF ADDENDUM #4

HURST-ROSCHE INC.
1101 Kermit Dr. Suite 620
Nashville, TN
615-454-6615