

**ADDENDUM NO. 1**

DATE: May 14, 2026

Hurst-Rosche, Inc.  
1400 E. Tremont Street  
Hillsboro, Illinois 62049

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 1 TO THE  
BIDDING DOCUMENTS FOR

S. Broad Street and E. Seward Street  
Watermain Replacement  
Hillsboro, Montgomery County, Illinois  
HR No. 850-1684



\_\_\_\_\_  
SIGNATURE

05-14-2026

\_\_\_\_\_  
DATE

11-30-2027

\_\_\_\_\_  
LICENSE EXPIRES

This addendum forms a part of the bidding and contract documents and modifies the bidding documents dated April 2026. Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

.....  
**UPON RECEIPT OF THIS ADDENDUM, PLEASE SIGN BELOW AND EMAIL FRONT PAGE TO [zyork@hurst-rosche.com](mailto:zyork@hurst-rosche.com) WITHIN 24 HOURS OF RECEIPT.**

\_\_\_\_\_  
Company Name/Authorized Signature

\_\_\_\_\_  
Date

.....  
Bid Opening Date is: 10:00 AM, Wednesday, May 20, 2026

**Bidders are hereby informed that the construction documents and/or drawings are modified as follows:**

**CLARIFICATIONS:**

Question: How can we obtain a list of plan holders?

Answer: For plan holders list, please refer to our website, under contractors, for periodically updated plan holders list and any project addenda.

Question: Can the water service line connections be completed at any time after the newly replaced watermain has been tested, accepted, and placed in service?

Answer: No, please see the Watermain Connection Note on Plan Sheet C-101. The Contractor will be required to complete all watermain connections for all the water service lines during non-business hours so that the commercial businesses can remain open during normal business hours. All watermain connections shall be scheduled and coordinated with the City and all the business owners that will be affected.

Question: Who do we need to coordinate with for this project since the construction is within an existing street and right of way?

Answer: Contractor will need to coordinate with all local authorities including the City, Fire Department, any local businesses, and any other local emergency management agencies for road closures and access through or around the project site. Emergency vehicle and all fire and rescue vehicle access will be critical for the work based on the location adjacent to the existing Hillsboro Fire Department fire house along S. Broad Street. E. Seward Street can be shut down to traffic for specific workday activities with coordination with the City and will need to be reopened at night. Please coordinate with the City and all local authorities during construction.

Question: Does the City want to salvage any of the bricks from the existing roadway for any historical purpose?

Answer: If possible, the City would like to salvage some of the bricks from the existing roadway during construction and excavation that are not rubble. The City is not looking to salvage all the bricks, just some that are not rubble. Any bricks in whole condition to be set aside for the City to collect. Contractor to coordinate directly with the City on this task.

Question: Is there a form or any specific format required for the "bidder's qualifications statement and supporting data" as referenced in the Bid Form, Part 1, Paragraph 1.10.A., Appendices?

Answer: For the bidder's qualifications statement and supporting data, there is no particular form for this information, and the Bidder can send whatever company profile information they would like for the bidder's qualifications statement and supporting data. One reference that could be used is AIA Document A305 - Contractor's Qualification Statement. Please note the AIA form is not required to be used for this request, but the AIA form can be used as a reference to submit the bidder's qualifications statement and supporting data.

Question: Is there a form or any specific format required for the bid bond or can the surety company use their own form or format?

Answer: For the bid bond, there is no particular form, and the surety company can use their own standard form or format for the bid bond submittal.

Question: Are there any domestic requirements (AIS/BABA) for this project?

Answer: No, this project is locally funded and does not have any domestic requirements (AIS/BABA) per funding agency requirements. With this being, in the specifications Section 33 11 13, Part 2, Paragraph 2.1.E., it states all iron, steel, and fittings shall be the product of a United States of America manufacturer. Based on this, please use domestic products for this project per the specifications.

**END ADDENDUM NO. 1**