

DATE: April 6, 2020

HURST-ROSCHE, INC.
1400 E. Tremont Street
Hillsboro, Illinois 62049
217-532-3959

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 3 TO THE BIDDING DOCUMENTS FOR

HVAC REPLACEMENT
HILLSBORO HIGH SCHOOL – GYM BUILDING
HILLSBORO C.U.S.D. NO. 3
HILLSBORO, MONTGOMERY COUNTY, ILLINOIS
HR # 150-3209

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated March 18, 2020. Acknowledge receipt of this addendum in the space provided on the Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

Upon receipt of this addendum, please sign below and email to Hurst-Rosche, Inc. at tdownen@hurst-rosche.com within 24 hours of receipt.

RECEIVED BY:	_____
	Company Name/Authorized Representative
DATE:	_____

DRAWINGS

- A. Sheet M-101
 - 1. **REVISE** Keyed Note No. 10 to state: “INSTALL NEW DUCT SMOKE DETECTOR (SYSTEM SENSOR MODEL D4120-4 WITH DST10 SAMPLING TUBE AND RTS151 KEYED SWITCH RESET) IN RETURN DUCT OF AIR HANDLING UNIT. ROUTE 4-#18 AWG WIRING IN A ½” EMT CONDUIT TO THE EXISTING FIRE ALARM CONTROL PANEL LOCATED IN THE BASEMENT. BOTH DUCT DETECTORS SHALL BE INSTALLED ON ONE LOOP TO THE CONTROL PANEL. THE EXISTING FIRE ALARM CONTROL PANEL IS MANUFACTURED BY FIRELITE ALARMS SENSISCAN 1000. THE EXISTING FIRE ALARM SYSTEM IS MAINTAINED/SERVICED BY WAREHAM’S SECURITY, TAYLORVILLE, IL, WENDY KELLER (1-800-500-8514).”

This addendum consists of 2 pages.

This addendum **DOES NOT** change the previously published bid date / time of **April 9, 2020, 3:00 PM** prevailing time, all at **Hillsboro C.U.S.D. No. 3 Unit Office, 1311 Vandalia Road, Hillsboro, Illinois.**

Sincerely,
HURST-ROSCHE, INC.



Timothy L. Downen, AIA, LEED AP
cc: All plan holders

This addendum consists of 2 pages.