

DATE: 04-5-2021

HURST-ROSCHE, INC.
1400 E. Tremont Street
Hillsboro, Illinois 62049
217-532-3959

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 2 TO THE BIDDING DOCUMENTS FOR

SECURITY VESTIBULES
WIRTH MIDDLE SCHOOL AND OLIVER PARKS SCHOOL
CAHOKIA USD #187
CAHOKIA, ST. CLAIR COUNTY, ILLINOIS
HR # 150-0091

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated March 22, 2021. Acknowledge receipt of this addendum in the space provided on the Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

Upon receipt of this addendum, please sign below and email to Hurst-Rosche, Inc. at tdownen@hurst-rosche.com within 24 hours of receipt.

RECEIVED BY:	_____
	Company Name/Authorized Representative
DATE:	_____

SPECIFICATIONS

- A. 08 80 00 Glazing
 - 1. **DELETE** Paragraph 2.2.A.2 and Paragraph 2.2.A.3.

- B. 12 30 40 General Casework
 - 1. **ADD** “Ideal Cabinet Solutions, Inc.” as Paragraph 2.1.A.9.

This addendum consists of 2 pages.

DRAWINGS

- A. A-201 SCHEDULES, DOOR & FRAME ELEVATIONS, & ADA GUIDELINES
1. **DELETE** “3 feet 4 inches” as the width of Door 120 in DOOR SCHEDULE and **REPLACE** it with, “3 feet 8 inches”.
 2. **DELETE** “7 feet 6 inches +/-“ as the width of door frame D in 1/A-201 FRAME ELEVATIONS and **REPLACE** it with, “4 feet 4 inches +/-“.
 3. **DELETE** “4 feet 0 inches +/-“ as the width of sidelite glazing of door frame D in 1/A-201 FRAME ELEVATIONS and **REPLACE** it with, “10 inches +/-“.
 4. **DELETE** “7 feet 2 inches” as the height of Door 103 in DOOR SCHEDULE, and **REPLACE** it with, “7 feet 0 inches”.
 5. **DELETE** “#” from Hardware Set column of Door 110 in DOOR SCHEDULE, and **REPLACE** it with, “1”.

This addendum **DOES NOT** alter the previously published bid date of **Thursday, April 8, 2021, 2:00 PM**, prevailing time, at **Cahokia USD #187 Unit Office, 1700 Jerome Lane, Cahokia, Illinois**.

Sincerely,

HURST-ROSCHE, INC.



Timothy L. Downen, AIA, LEED AP
cc: All plan holders

This addendum consists of 2 pages.