

DATE: 03-05-2020

HURST-ROSCHE, INC.  
1400 E. Tremont Street  
Hillsboro, Illinois 62049  
217-532-3959

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 2 TO THE BIDDING DOCUMENTS FOR

**Calhoun High School Door Replacement**  
**Calhoun Unit District 40**  
**Hardin, Calhoun County, Illinois**  
**HR # 270-2896**

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated February 17, 2020. Acknowledge receipt of this addendum in the space provided on the Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

\*\*\*\*\*

**Upon receipt of this addendum, please sign below and email to Hurst-Rosche, Inc. at [tdownen@hurst-rosche.com](mailto:tdownen@hurst-rosche.com) within 24 hours of receipt.**

RECEIVED BY: _____ Company Name/Authorized Representative
DATE: _____

**DRAWINGS**

- A. SHEET A-103
  - 1. **DELETE** “1 INCH FIRE RATED GLASS” and “1 INCH FIRE RATED GLASS WITH SECURITY FILM” from Door Frame and Elevation Legend. **REPLACE** both with, “1 HOUR FIRE RATED GLASS.” Security film will not be required at this door and door frame.

This addendum consists of 2 pages.

## SPECIFICATIONS

### A. Section 08 80 00

1. **DELETE** "FireLite Plus or Pyran Platinum L" from Paragraph 2.3.A and **REPLACE** it with, "Firelite Plus NT or Pyran Platinum F".
2. **DELETE** Paragraph 2.3.A.2 and **REPLACE** it with, "Glass Thickness: 3/16 inch."
3. **DELETE** Paragraph 2.3.A.4 and **REPALCE** it with, "Weight: Approximately 2.5 pounds per square foot."
4. **DELETE** Paragraph 2.3.A.5 in its entirety.

This addendum **DOES NOT** alter the previously published bid date of **March 10, 2020, 2:00 PM**, prevailing time, at **Calhoun Unit District 40 Unit Office, 101 Calhoun Avenue, Hardin IL**.

Sincerely,

HURST-ROSCHE, INC.



Timothy L. Downen, AIA, LEED AP

cc: All plan holders