

DATE: 2-17-2021

HURST-ROSCHE, INC.
1400 E. Tremont Street
Hillsboro, Illinois 62049
217-532-3959

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 1 TO THE BIDDING DOCUMENTS FOR

ASBESTOS FLOOR TILE ABATEMENT
BECKEMEYER ELEMENTARY SCHOOL AND HILLSBORO HIGH SCHOOL
HILLSBORO, MONTGOMERY COUNTY, ILLINOIS
HR # 150-0511

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated February 15, 2021. Acknowledge receipt of this addendum in the space provided on the Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

Upon receipt of this addendum, please sign below and email to Hurst-Rosche, Inc. at tdownen@hurst-rosche.com within 24 hours of receipt.

| | |
|---------------------|---|
| RECEIVED BY: | _____ |
| | Company Name/Authorized Representative |
| DATE: | _____ |

DRAWINGS

- A. ASB-101
 - 1. **DELETE** the text description for the cross hatch portion of the legend dealing with carpet and **REPLACE** it with, “EXISTING CARPET AND GLUE TO BE REMOVED BY ABATEMENT CONTRACTOR. ALL WALL BASE MATERIAL AND WALL BASE MASTIC TO BE REMOVED AS NON-ASBESTOS CONTAINING MATERIAL.”

This addendum consists of 2 pages.

2. **ADD** Keyed Note #5 as follows, “CARPET MASTIC CONTAINS TRACE AMOUNTS OF ASBESTOS. ABATEMENT CONTRACTOR TO REMOVE CARPET AND MASTIC UTILIZING WET REMOVAL METHODS AND PROMPTLY CLEAN UP MATERIAL / DEBRIS AND PLACE IN LEAK TIGHT CONTAINERS. A NEGATIVE EXPOSURE ASSESSMENT IS TO BE COMPLETED OR MADE AVAILABLE BY THE ABATEMENT CONTRACTOR FOR THIS TYPE OF WORK.”
3. **ADD** Keyed Note symbol #5 to OFFICE 111 on the floor plan.

This addendum **DOES NOT** alter the previously published bid date of **Thursday, March 4, 2021, 2:00 PM**, prevailing time, at **Hillsboro C.U.S.D. No. 3 Unit Office, 1311 Vandalia Road, Hillsboro, IL 62049**.

Sincerely,

HURST-ROSCHE, INC.

A handwritten signature in black ink, appearing to read 'T. Downen', with a long horizontal flourish extending to the right.

Timothy L. Downen, AIA, LEED AP
cc: All plan holders

This addendum consists of 2 pages.

009115-2