

DATE: June 10, 2022

HURST-ROSCHE, INC.
No. 5 Bank Square
East St. Louis, Illinois 62203
Phone: 618.398.0890

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 1 TO THE BIDDING DOCUMENTS FOR

LIFT STATION REHABILITATION PY21
POCKET ROAD & MISSOURI AVENUE
HR 211-0462

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated May, 2022. Acknowledge receipt of this addendum in the space provided on the Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

Upon receipt of this addendum, please sign below and email to Hurst-Rosche, Inc. at tsudholt@hurst-rosche.com within 24 hours of receipt.

<p>RECEIVED BY: _____ Company Name/Authorized Representative</p> <p>DATE: _____</p>

CLARIFICATIONS

1. The specs make it sound like the existing service pole is being changed out, along with the entire existing service.

The existing service pole, including service to the pole, is intended to be reused.

2. Drawing #3 shows using the existing wiring from the control panel to the wet well. I would assume that the cables for the pump and the level sensing probe will be provided by the supplier of the pump and level sensor.

Yes, the cables for the pumps and the level sensing probes will be provided by the supplier of the pumps and level sensors.


3. The existing conduit and seals should be sealed with sealant that will not enable the seal, and any conduit and wiring that has been infiltrated with the sealant, to be reused. Do you want me to leave replacing the seals and any associated conduit out of our proposal? We could always come back with a change order later if that's how you want me to quote it.

Conduits from the control panel to the wet well need to be sealed as part of the base bid.

This addendum **DOES NOT** alter the bid date of **Thursday, June 16, 2022, 10:00 am** prevailing time, at office of Hurst-Rosche Engineers, Inc. 5 Bank Square, East St. Louis, IL.

Respectfully submitted,

HURST-ROSCHE, INC.



Terry A. Sudholt, PE

TAS/jc

This addendum consists of 1 page.