

DATE: July 11, 2022

HURST-ROSCHE, INC.
No. 5 Bank Square
East St. Louis, Illinois 62203
Phone: 618.398.0890

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 1 TO THE BIDDING DOCUMENTS FOR

LIFT STATION REHABILITATION
TWO LOCATIONS
HR 211-0741

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated May, 2022. Acknowledge receipt of this addendum in the space provided on the Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

Upon receipt of this addendum, please sign below and email to Hurst-Rosche, Inc. at tsudholt@hurst-rosche.com within 24 hours of receipt.

RECEIVED BY: _____ Company Name/Authorized Representative
DATE: _____


CLARIFICATIONS

1. The existing eductor stations shall be removed in their entirety. The existing stations are 5'-0" diameter by 4'-0" tall. The bottom of the eductor stations are 1'-0" below grade and are supported on two 4" by 6'-4" long I-beams resting on a 4'-0" by 7'-0" by 8" thick reinforced concrete pad.
2. The existing 16" casing pipes to be filled with grout at the 320 and 352 N. 82nd Street locations are 20' and 16' long respectively.

This addendum **DOES NOT** alter the bid date of **Thursday, July 14, 2022, 10:00 am** prevailing time, at office of Hurst-Rosche Engineers, Inc. 5 Bank Square, East St. Louis, IL.

Respectfully submitted,

HURST-ROSCHE, INC.



Terry A. Sudholt, PE
TAS/jc